



## Release of OJ-Air2 software version 4.13

OJ-Air2 software version 4.13 is released for up-grade with the SD-card. In the production at OJ Electronics the version 4.10 is still used, until further notice.

### Changes

Compared to version 4.10 there were following improvements:

#### Functionality

- *Min. Cooling time* is now active even if *Max. restart pr. Hour* is set to 0.  
*Min. Cooling time* and *Min. Stop time* is now always active. They can individually be disabled by setting the time to 0.
- Ext. rotary switch now supports
  - Operation mode via BMS
  - External low speed
  - External medium speed
  - Start – External signal
- Check mark “Firedamper open in stop” saved during power off.

#### Web

- No changes

#### Hand terminal

- No changes.

#### OJ-Air2-HMI-35T

- *Max. stop time* value increased from 23:45 to 24:00 hours in the Weekly program.

#### Alarms

- No changes

#### Modbus registers

- No changes

#### BACnet

- No changes

## Affected articles

OJ-Air2Master

## Coming into force

Version 4.13 is released for up-grade with SD-Card in week 22 2017.

## Compatibility

No changes are required when up-grading from version 4.10 to 4.13.

## Updating with the SD card

The OJ-Air2Master has to be with software version 2.01 or higher.

Following files must be copied to the SD card:

- "air2\_v413\_update\_jffs2.tar.gz"
- " version.crc" (1kB, 27-04-2017, 13:46)

The files are available at:

<http://www.ojelectronics.com/Support/Customer-Login.aspx>

Up till 8Gb HC SD cards can be used from version 2.19.

